

WELL COMPLETION REPORT

3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

LAKE CARMEL

41 29 39 73 39 50

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1078

OWNER	NAME Paul Desiano		ADDRESS Beekman Drive, Lk. Carmel, NY	
LOCATION OF WELL	(No. & Street) Beekman Drive		(Town) Lk. Carmel	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify) 670 L
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
CASING DETAILS	LENGTH (feet) 30'5"	DIAMETER (inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 2 G.P.M. 15 YIELD (G.P.M.) 15
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 25		DURING YIELD TEST (feet) 165	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches): GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
0	17	Clay and boulders.	
17	22	Weathered ledge.	
22	165	Hard gray granite.	
If yield was tested at different depths during drilling, list below			Beekman Drive
FEET	GALLONS PER MINUTE		

DATE WELL COMPLETED 11/10/73	DATE OF REPORT 11/20/73	WELL DRILLER (Signature) Robert M. Mill	President MILL DRILLING, INC.
---------------------------------	----------------------------	--	----------------------------------